## RESCINDED BY BUILDINGS BULLETIN 2022-003



## DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES
60 HUDSON STREET. NEW YORK. N. Y. 10013
CHARLES M. SMITH. Jr., R.A., Commissioner
312-8100

January 29, 1990

GEORGE E. BERGER, P.E. Acting Deputy Commissioner Technical Affairs (212) 312-8120

Mr. Daniel M. McGee, P.E. American Iron & Steel Institute Matawan Mall P.O. Box 311 34th & Broad Street Matawan, New Jersey 07747

Re: Plastic Piping

Dear Mr. McGee:

Your letter of December 1, 1989 addressed to Commissioner Smith has been referred to my office for review and reply.

As indicated in your letter to this office regarding the use of non-metalic pipe for fire sprinkler system, your understanding is correct in that such use has been under review.

B. F. Goodrich has filed an MEA Application 434/88M for acceptance of their Blaze Master Sprinkler Pipe, C-PVC, to be used for use in a sprinkler system. Numerous tests were submitted to our MEA Division in regard to MEA Application 434/88M. In reviewing these test results, Deputy Commissioner Dennis submitted a memo to Marvin Hassman, Director of MEA, allowing B. F. Goodrich Blaze Master Sprinkler Pipe under that MEA Application to be used for residential occupancies.

Such pipe may only be used when located in spaces protected by sprinklerheads fed from that pipe and only when the system is a wet sprinkler system.

Sincerely,

George E. Berger, P.E. (
Acting Deputy Commissioner